

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20190731-EX28032  
**Report Reference** EX28032-20190730  
**Issue Date** 2019-JULY-31

**Issued to:** FAS SPA  
Via Della Meccanica 18  
27010 CURA CARPIGNANO PV ITALY

**This certificate confirms that representative samples of** FOAM MONITORS  
Please see addendum page

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 162, UL Standard for Safety for Foam Equipment and Liquid Concentrates

**Additional Information:** See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20190731-EX28032  
**Report Reference** EX28032-20190730  
**Issue Date** 2019-JULY-31

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Monitor	Nozzle	Type	Nozzle Inlet Pressure psi	Solution Flow GPM
MB3 L	Branchpipe LS 3	B,D	44-102	347-527
MB3 2V	Branchpipe LS 3	B,D	44-107	361-544
MBA3 L	Branchpipe LS 3	A,D	44-102	357-542
DOC 2V	Branchpipe LS 4	B,D	44-93	549-823

A – Oscillating

B – Nonoscillating

C - Self-inducting

D - Non-self-inducting



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

